



CITY OF SANTA ANA

---

**FINANCE & MANAGEMENT SERVICES DEPARTMENT  
PURCHASING DIVISION  
20 CIVIC CENTER PLAZA, RM 429 (M-16)  
P.O. BOX 1988, SANTA ANA, CA 92702 (714) 647-5460**

January 26, 2012

**ADDENDUM NO. 1**

**CORBIN CENTER RE-ROOFING PROJECT  
IFB 12-013**

The following change have been made to IFB 12-013.

- Correction to dry mils thickness  
Page 11, item 8, a and b.

Corrected to read:

- a. Coating warranty for 10 years has a minimum 30 dry mils thickness.
- b. Coating warranty for 15 years has a minimum 35 dry mils thickness.

All other terms and conditions remain the same.

Sincerely,

*Katie Montgomery*

Katie Montgomery  
Buyer – City of Santa Ana  
714 647-5466, Fax 714 647-6944  
[Kmontgomery@santa-ana.org](mailto:Kmontgomery@santa-ana.org)