



| CONSTRUCTION ITEMS / MATERIALS LIST | | | |
|-------------------------------------|---|------------------------------------|---------------|
| NO. | SIZE AND DESCRIPTION | MANUFACTURER/MATERIAL | MFR. CAT. NO. |
| 1 | CAST IRON FRAME AND COVER ("SEWER") | ALHAMBRA FOUNDRY OR APPROVED EQUAL | A-2100 |
| 2 | SDR-35; PVC SEWER PIPE -4" MIN. IF SERVING 4 DWELLINGS OR LESS -6" MIN. ALL OTHER CASES | SDR-35 | |
| 3 | CONSTRUCT CONCRETE SIDEWALK PER CITY STD. PLAN 1104 | | |
| 4 | CONCRETE SHALL BE CLASS 420-C-2000, POURED FULL WIDTH OF TRENCH | | |
| 5 | SDR-35; MALE THREADED NUT PLUG | | |
| 6 | WYE SHALL MATCH EXIST. SEWER MAIN MATERIAL | SDR-35 PVC OR V.C.P. | |
| 7 | 45° ELBOW SHALL MATCH WYE MATERIAL | SDR-35 PVC OR V.C.P. | |
| 8 | SDR-35; REDUCER (IF NECESSARY) | | |
| 9 | COUPLING ADAPTER (IF NECESSARY) | | |
| 10 | SDR-35; PVC WYE | | |
| 11 | 45° PVC ELBOW | | |

NOTE:

1. MIN. LATERAL SLOPE SHALL BE 1/4" PER FOOT (2%).

APPROVED:

DATE:

8/10/09

[Handwritten Signature]

CITY OF SANTA ANA
PUBLIC WORKS AGENCY



| DATE | | REVISION |
|---------|------|---------------------------|
| 8/19/03 | A.F. | NEW DETAIL |
| 7/16/09 | R.R. | CHANGED MIN. LATERAL SIZE |

SEWER LATERAL
AND CLEANOUT

STD. PLAN
NUMBER
1204