



D = OUTSIDE DIAMETER

NOTE: MINIMUM TRENCH WIDTH FOR ALL SUBSTRUCTURES = 6"

NOTES:

1. If trenchwalls slough so as to remove firm support to adjacent pavement, such pavement shall be removed back to where firm support is available. the removal of pavement under such conditions shall be for a minimum distance of 10 feet along the trench, and the width of removal shall be constant and equal to the greatest dimension required for removal to firm support.
2. Pavement replacement shall be done according to City of Santa Ana standard plan numbers 1150a and 1150b.
3. See standard plans no. 1150a and 1150b for backfill requirements.
4. Compact the sand bedding using jetting methods per std. specifications sec. 306-1.3.

STD. PLAN NO'S 1150 THRU 1150C REPLACES STD. PLAN NO'S 1206 THRU 1206D.

APPROVED: DATE: 1-22-01

[Signature]
CITY ENGINEER

◦ CITY OF SANTA ANA ◦
PUBLIC WORKS AGENCY



DATE		REVISION
12/03/96	SA	REVISED NOTE #3
06/01/00	SA	REVISED NOTE AND DETAIL
12/14/00		REVISED STANDARD PLAN NUMBER

EXCAVATION & BEDDING DETAILS

STD. PLAN NUMBER
1150C