



GENERAL NOTES

1. PRESSURE TEST AND CHLORINATION TO LIMITS SHOWN ABOVE
2. BACKFLOW ASSEMBLY SHALL BE A MINIMUM OF 36" FROM ANY STRUCTURE, CURB OR SIDEWALK.
3. BACKFLOW ASSEMBLY MUST BE EASILY ACCESSIBLE TO FACILITATE TESTING AND SERVICING
4. THE USC LIST OF APPROVED BACKFLOW PREVENTION ASSEMBLIES HAS BEEN ADOPTED BY CITY WATER DEPARTMENT AS THE ONLY ASSEMBLIES APPROVED FOR USE ON THE WATER LINES UNDER OUR JURISDICTION.
5. PRIVATE WATER APPURTENANCES SUCH AS BACKFLOW PREVENTERS, FIRE HYDRANTS AND STANDPIPES, AND VALVES SHALL BE PAINTED AS FOLLOWS:
 - DOMESTIC WATER (BLUE)
 - POTABLE IRRIGATION (GREEN)
 - RECYCLED IRRIGATION (PURPLE)
 - FIRE PROTECTIONS (OSHA SAFETY RED)

"FOR DOMESTIC USE ONLY"
HEALTH HAZARD (CONTAMINANT) BACKFLOW PREVENTION DEVICE



APPROVED: DATE: 3/8/2014

Maria Sasa

CITY OF SANTA ANA
PUBLIC WORKS AGENCY

DATE	R.R.	REVISION
3/1/16		NEW

REDUCED PRESSURE PRINCIPLE
ASSEMBLY (3" OR LARGER)

STD. PLAN
NUMBER
1434